### Key Features

- IEC-61158-2, H1 (ISA-S50.02-1992), Type 111 and Type 112 (FF-816) compliant
- -40°C to 85°C
- 44-pin plastic LQFP (Green/RoHS compliant)
- Low current consumption: 500µA typical
- Standard MDS/MAU interface
- 31.25kbps voltage mode
- Dual voltage regulators (3 and 6.2V)
- Voltage level monitoring

## Product Description

The AMIS-49200 Fieldbus Medium Attachment Unit (MAU) can be used in applications that meet the Foundation Fieldbus and Profibus PA standards. It is compatible with requirements of the IEC-61158-2, H1 (ISA-S50.02-1992, EN 50170 (formerly DIN 19245)) physical layer standard.

The AMIS-49200 Fieldbus MAU is a near pin-for-pin replacement for Yokogawa  $\mu$ SAA22Q. This includes the elimination of some capabilities and specifications of the  $\mu$ SAA22Q.

## Normal Operating Conditions



In most applications, the AMIS-49200 can be used as a replacement for the  $\mu$ SAA22Q. Some external component values may have to be changed but, in most cases, the layout of the circuit board will not have to change.

Parameter	Symbol	Min.	Тур.	Max.	Units	Conditions
Analog Supply Voltage	VCC	4.75	5	6.2	V	Supply voltages are configurable or can be supplied from off-chip
Digital Supply Voltage	VDD	2.7	3	VCC - 1.1V	V	Supply voltages are configurable or can be supplied from off-chip
Operating Temperature	Toperating	-40		85	°C	
Current Compensation	ICC		500	800	μΑ	25°C, SHUNT current = 1mA, No current from series regulator

# **CMOS** Parameter Specifications

CMOS Parameter Specs	Symbol	Min.	Max.	Units
Input High Voltage	VIH	0.7 • Vdd	Vdd	V
Input Low Voltage	VIL	0	0.3 • Vdd	V
Input High Current	Ін		1	μΑ
Input Low Current	liL		-1	μA
Schmitt Negative Threshold	Vt-	0.2 • Vdd		V
Schmitt Positive Threshold	Vt+		0.8 • Vdd	V
Schmitt Hysteresis	Vh	1		V

## Ordering Codes

Marketing Name	Description	Device No.
AMIS-49200	Fieldbus MAU Chip	19699-002-XTD (tray) or -XTP (tape & reel)
EVK-49200	AMIS-49200 Evaluation Kit	EVK-49200



#### 44 PIN LQFP Pin Diagram and Cross-Reference Table



Pin No.	µSAA22Q	AMIS-49200
1	NC	TEST1
11	NC	GND
18	VCC	VCC
22	NC	GND
26	NC	TEST2
33	NC	GND
39	JAB/	GND
41	CJB	TEST3
42	VTX	TEST4
43	VSL	TEST5
44	VCC	VCC

Differences between the AMIS-49200 Fieldbus MAU and the Yokogawa  $\mu\text{SAA22Q}$  are listed in the cross-reference table.

Pins 11, 22 and 33 may be left N/C, however, we recommend connecting them to ground to improve noise immunity.

Pin 39 is the ground for the voltage reference and must be connected to system ground.

TEST1 – TEST5 must be connected to ground.

The AMIS-49200 was designed to have excellent EMC performance. In order to achieve the full performance, VCC Pins 18 and 44 should be connected together.

#### Block Diagram





#### AMI Semiconductor

#### www.amis.com

Devices sold by AMIS are covered by the warranty and patent indemnification provisions appearing in its Terms of Sale only. AMIS makes no warranty, express, statutory, implied or by description, regarding the information set forth herein or regarding the freedom of the described devices from patent infringement. AMIS makes no warranty of merchantability or fitness for any purposes. AMIS reserves the right to discontinue production and change specifications and prices at any time and without notice. AMI Semiconductor's products are intended for use in commercial applications. Applications requiring extended temperature range, unusual environmental requirements, or high reliability applications, such as military, medical life-support or life-sustaining equipment, are specifically not recommended without additional processing by AMIS for such applications. Copyright ©2007 AMI Semiconductor, Inc. M-20534-002